

From: [Hermansen, Heather E](#)
To: [Hermansen, Heather E](#)
Subject: Flaming Gorge Notification - November 10, 2011
Date: Thursday, November 10, 2011 5:10:39 PM

Hello:

Flaming Gorge Dam maintenance has been completed and two units are available for generating capacity. Therefore, beginning November 13, 2011, Flaming Gorge will be operated at an average daily release rate of 1,500 cfs/day according to the schedule below.

	11/12/11 1,500 cfs daily	11/13/11 1,500 cfs daily
Time (MPT)	Total Release (cfs)	Total Release (cfs)
0:00	1,500	817
1:00	1,500	817
2:00	1,500	817
3:00	1,500	817
4:00	1,500	817
5:00	1,500	1,604
6:00	1,500	1,635
7:00	1,500	1,635
8:00	1,500	1,635
9:00	1,500	1,635
10:00	1,500	1,635
11:00	1,500	1,635
12:00	1,500	1,635
13:00	1,500	1,635
14:00	1,500	1,635
15:00	1,500	1,635
16:00	1,500	1,635
17:00	1,500	1,635
18:00	1,500	1,635
19:00	1,500	1,635
20:00	1,500	1,635
21:00	1,500	2,240
22:00	1,500	2,240
23:00	1,500	1,332

Please note: The starting times are NOT HOUR ENDING, but are set to LOCAL TIME (Mountain Prevailing Time).

Flaming Gorge information for the last five days is shown below.

Flaming Gorge	Elev (ft)	Inflow (cfs)	Unreg Inflow (cfs)
11/05/11	6,032.31	1,576	1,264
11/06/11	6,032.31	1,576	1,228
11/07/11	6,032.31	1,574	1,153
11/08/11	6,032.29	1,160	704
11/09/11	6,032.27	1,168	676

Further information can be found here: http://www.usbr.gov/uc/water/rsvrs/ops/crsp_40_fgd.html

Heather E. Hermansen
Hydraulic Engineer
Bureau of Reclamation
125 South State Street, UC-436
SLC, UT 84138-1147
PH: 801-524-3883
hhermansen@usbr.gov

Please note my email has changed to hhermansen@usbr.gov